

Table 2-1. Typical Product Gas Composition¹

Component	Product Gas Composition (Volume %)
Methane	15.61
Ethylene	5.26
Ethane	0.68
Carbon Monoxide	45.8
Carbon Dioxide	11.03
Hydrogen	20.7
Water Vapor	0.22
Hydrogen Sulfide	0.02
Nitrogen	0.68
Heating Value (Btu/scf) LHV	435.4

¹ Analysis provided by SilvaGas

Table 2-2. Startup and Shutdown Emissions Summary

Emission Component	Source	Turnaround		Emergency		Controlled		Total Annual Emissions (TPY)
		Shutdowns, TPY	Start-up, TPY	Shutdowns, TPY	Start-up, TPY	Emissions, TPY	Emissions, TPY	
NOx	Combustion Duct Burner		0.06					
	Gasifier Duct Burner		0.09					
	Char		0.36					
	Wood Combustion		3.56					
Total NOx	Gasifier Island	0.025	0.82	0.05				
		0.025	4.89	0.05				4.965
PM ₁₀		0.0025	0.51	0.0005		0.01		0.523
PM		0.0025	0.51	0.0005		0.01		0.523
Based upon information from SilvaGas								

**TABLE 3-1
BG&E PROJECT SUMMARY OF POTENTIAL AIR EMISSIONS**

Pollutant (TPY)	CTs/DBs (1A & 1B)	Gasifier Combustor	Cooling Tower	Material Handling	Auxiliary Boiler	Flare	Dryer	Total Emissions
SO ₂	71.8	10.7			0.09	0.80		83
PM	63.0	26.7	0.04	24.0	0.03	neg	0.10	114
PM ₁₀	63.0	26.7	0.04	24.0	0.03	neg	0.01	114
NO _x	167.4	27.2			1.47	0.70		197
CO	187.6	11.2			1.24	3.80		204
VOC (as methane)	10.9	5.6			0.08	1.50		18
Fluoride	neg	neg						0
Lead	neg	neg						0
Total HAPs	4.0	0.9						5

* Based on emissions at 59F.

Table 3-2. Combustion Turbine and Duct Burner Emissions

BGE POWER PLANT STANDARD EMISSIONS

SOLAR TURBINES

Annual Hour Basis: 8760

Emissions at Full Load Operations

Temp F	25	59	95
GTU Fuel (MMBtu/hr LHV)	157.4	146.9	132.4
Each	314.9	293.7	264.8
Total			

HRSG Duct Burner Emission Rate (lb/MMBtu LHV)

Nox	0.15
CO	0.08
UHC	0.03
Pm	0.01

GTU Pm Emissions

0.0413 lb/MMBtu HHV

Unfired Duct Duct Burner Cases

Rev B: No change in emissions - changes in Silica Steam to reflect reduced fuel production
Rev C: Revised Fired Case capacity, added stack dia of 78 inches

Fuel Available 378 MMBtu/hr LHV

Reduction: 90%

Ambient Temp F	EMISSIONS ARE FOR ONE UNIT - TWO REQUIRED																						
	Gas Turbine Outlet (80-100%)					Duct Burner Contribution					After Duct Burner / Before SCR					After SCR (Stack Outlet) Nox Reduction of 90%							
	GTU Exh Flow pph	Exh Temp F	Nox ppm	CO ppm	UHC ppm	NH3 ppm	Duct Burner Mass Flow	Nox ppm	CO ppm	UHC ppm	NH3 ppm	Mass Flow pph	Nox ppm	CO ppm	UHC ppm	NH3 ppm	Stack Exh Flow pph	Exh Temp F	Nox ppm	CO ppm	UHC ppm	NH3 ppm	
25	378.0	916	325.0	50.0	25.0	0.0	0.0	0.0	0.0	0.0	0.0	197.9	18.5	5.3	0.0	0.0	19.8	18.5	5.3	0.0	0.0	2.2	
59	378.0	916	325.0	50.0	25.0	0.0	0.0	0.0	0.0	0.0	0.0	184.0	17.2	4.9	0.0	0.0	16.4	17.2	4.9	0.0	0.0	2.0	
95	378.0	916	325.0	50.0	25.0	0.0	0.0	0.0	0.0	0.0	0.0	163.4	15.3	4.4	0.0	0.0	16.3	15.3	4.4	0.0	0.0	1.8	
Temp F																							
25	TPY	867.0	81.2	23.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	867.0	81.2	23.2	0.0	0.0	86.7	81.2	23.2	0.0	0.0	9.5	
59	TPY	806.1	75.5	21.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	806.1	75.5	21.5	0.0	0.0	80.6	75.5	21.5	0.0	0.0	8.8	
95	TPY	715.9	67.1	19.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	715.9	67.1	19.1	0.0	0.0	71.6	67.1	19.1	0.0	0.0	7.8	

Fired Duct Duct Burner Maximum 56.5 MMBtu/hr LHV Fuel/Duct Burner

Temp F	25	59	95
Total Fuel Available	378.0	378.0	378.0
Fuel/Train	189.0	189.0	189.0
GTU Fuel/Train	157.4	146.9	132.4
HRSG Fuel/Train	31.50	42.0	56.5

Stack Diameter 78 inches

HRSG Performance per Train (Typ 2)			Total Available Steam @ Full Load		
Ambient Temp F	HRSG 1	HRSG 2	Ambient Temp F	HRSG 1	HRSG 2
25	31.5	75.463	25	75.463	47.000
59	42.0	83.750	59	83.750	47.000
95	56.5	98.064	95	98.064	47.000

Total Unfired Steam Full Load			Total Seam Production		
Ambient Temp F	HRSG 1	HRSG 2	Ambient Temp F	HRSG 1	HRSG 2
25	48.549	48.549	25	48.549	48.549
59	48.033	48.549	59	48.033	48.549
95	48.547	48.547	95	48.547	48.547

EMISSIONS ARE FOR ONE UNIT - TWO REQUIRED

Reduction: 90%

Ambient Temp F	Gas Turbine Outlet										After Duct Burner / Before SCR										After SCR (Stack Outlet) Nox Reduction of 90%									
	Gas Turbine Outlet					Duct Burner Contribution					After Duct Burner / Before SCR					After SCR (Stack Outlet) Nox Reduction of 90%					Pm GTU Only					PM HRSG				
	GTU Exh Flow pph	Exh Temp F	Nox ppm	CO ppm	UHC ppm	NH3 ppm	Duct Burner Mass Flow	Nox ppm	CO ppm	UHC ppm	NH3 ppm	Mass Flow pph	Nox ppm	CO ppm	UHC ppm	NH3 ppm	Ambient Temp F	HRSG 1	HRSG 2	Stack Exh Flow pph	Exh Temp F	Nox ppm	CO ppm	UHC ppm	NH3 ppm	PM GTU Only	PM HRSG			
25	378.0	916	325.0	50.0	25.0	0.0	5.24	3.1	1.18	0.0	203.8	21.7	6.5	0.0	0.0	20.4	21.7	6.5	2.6	7.2	0.3	7.6	2.6	6.1	0.6	6.7				
59	378.0	916	325.0	50.0	25.0	0.0	6.98	4.2	1.57	0.0	191.9	21.4	6.5	0.0	0.0	19.2	21.4	6.5	2.6	7.2	0.5	7.2	2.6	6.1	0.6	6.7				
95	378.0	916	325.0	50.0	25.0	0.0	9.39	5.6	2.11	0.0	174.2	20.9	6.5	0.0	0.0	17.4	20.9	6.5	2.6	7.2	0.6	7.2	2.6	6.1	0.6	6.7				
Temp F																														
25	TPY	867.0	81.2	23.2	0.0	0.0	22.9	13.8	5.2	0.0	889.9	95.0	28.4	0.0	0.0	89.0	95.0	28.4	11.4	31.6	1.5	33.1	11.4	29.4	2.0	31.5				
59	TPY	806.1	75.5	21.5	0.0	0.0	30.6	18.3	6.9	0.0	856.7	93.8	28.4	0.0	0.0	83.7	93.8	28.4	11.4	29.4	1.5	31.5	11.4	29.4	2.0	31.5				
95	TPY	715.9	67.1	19.1	0.0	0.0	41.1	24.7	9.2	0.0	757.0	91.7	28.4	0.0	0.0	75.7	91.7	28.4	11.4	28.4	1.5	29.3	11.4	26.5	2.7	29.3				

**Table 3-3. Hazardous Air Pollutant Emission Factors and Emissions for the BG&E Project
Natural Gas and Product Gas-Firing**

Parameter	Emission Rate (lb/hr) firing Gas for Operating Conditions of Base Load (1)			Natural Gas Maximum Annual Emissions (TPY) (2)	
	25 F	59 °F	95 F	59 °F 1	59 °F 2
				CT/HRSG	CTs/HRSGs
Ambient Temperature (°F):					
HIR (MMBtu/hr):	157	147	132		
HAPs (Section 112(b) of Clean Air Act)					
1,3-Butadiene	0.000068	0.000063	0.000057	0.0003	0.0006
Acetaldehyde	0.0063	0.0059	0.0053	0.0257	0.0515
Acrolein	0.0010	0.0009	0.0008	0.0041	0.0082
Benzene	0.0019	0.0018	0.0016	0.0077	0.0154
Ethylbenzene	0.0050	0.0047	0.0042	0.0206	0.0412
Formaldehyde	0.403	0.427	0.403	1.8712	3.7423
Naphthalene	0.00020	0.00019	0.00017	0.0008	0.0017
Polycyclic Aromatic Hydrocarbons (PAH) (3)	0.00035	0.00032	0.00029	0.0014	0.0028
Propylene Oxide	0.0046	0.0043	0.0038	0.0187	0.0373
Toluene	0.0052	0.0048	0.0044	0.0212	0.0425
Xylene	0.010	0.009	0.008	0.0412	0.0824
Antimony	0.0	0.0	0.0	0.00	0.0000
Arsenic	0.0	0.0	0.0	0.00	0.0000
Beryllium	0.0	0.0	0.0	0.00	0.0000
Cadmium	0.0	0.0	0.0	0.00	0.0000
Chromium	0.0	0.0	0.0	0.00	0.0000
Lead	0.0	0.0	0.0	0.00	0.0000
Manganese	0.0	0.0	0.0	0.00	0.0000
Mercury	0.0	0.0	0.0	0.00	0.0000
Nickel	0.0	0.0	0.0	0.00	0.0000
Selenium	0.0	0.0	0.0	0.00	0.0000
HAPs (Total)	0.438	0.460	0.432	2.01	4.0

(1) Emissions based on the following emission factors and conversion factors for firing natural gas:

Emission Factors	Value	Reference
Sulfuric acid mist	5 %	Conversion of SO ₂ to SO ₃ in gas turbine
1,3-Butadiene (a)	0.43 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Acetaldehyde	40 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Acrolein	6.4 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Benzene	12 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Ethylbenzene	32 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Formaldehyde	0.091 ppmvd @15% O ₂	(see Table 15a)
Naphthalene	1.3 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Polycyclic Aromatic Hydrocarbons (PAH)	2.2 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Propylene Oxide (a)	29 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Toluene	33 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000. Database
Xylene	64 lb/10 ¹² Btu;	AP-42, Table 3.1-3. EPA 2000
Antimony	0.00E+00	
Arsenic	0.00E+00	
Beryllium	0.00E+00	
Cadmium	0.00E+00	
Chromium	0.00E+00	
Lead	0.00E+00	
Manganese	0.00E+00	
Mercury	0.00E+00	
Nickel	0.00E+00	
Selenium	0.00E+00	

(a) Based on 1/2 the detection limit; expected emissions are lower.

(2) Annual emissions based on ambient temperature of 59 °F firing gas for following hours: 8,760

(3) Assumed to be representative of Polycyclic Organic Matter (POM) emissions, a regulated HAP.

Table 3-3. (continued) Estimated HAP Emissions from Gasification Process

HAP	Feed (ug/g)	Feed (lb/hr)	Emission (lb/hr)	Emissions, (TPY)
Mercury	6.7 x 10 ⁻⁶ lb/ton wood	60,800	0.0002	0.0009
Arsenic	90	5.4	0.00081	0.003443
Cobalt	4	0.24	0.000036	0.000153
Molybdenum	16	0.96	0.000144	0.000612
Silver	5	0.3	0.000045	0.000191
Thallium	26	1.56	0.000234	0.000995
Zirconium	3.4	0.204	3.06E-05	0.00013
Sodium	4726	283.56	0.042534	0.18077
Potassium	4299	257.94	0.038691	0.164437
Cerium	2	0.12	0.000018	7.65E-05
Lithium	<1	0	0	0
Calcium	8721	523.26	0.078489	0.333578
Magnesium	4790	287.4	0.04311	0.183218
Barium	173	10.38	0.001557	0.006617
Strontium	152	9.12	0.001368	0.005814
Phosphorus	365	21.9	0.003285	0.013961
Antimony	4	0.24	0.000036	0.000153
Chromium	492	29.52	0.004428	0.018819
Copper	1239	74.34	0.011151	0.047392
Lead	66	3.96	0.000594	0.002525
Nickel	26	1.56	0.000234	0.000995
Tungsten	< 0.5	0	0	0
			Total	0.965

Table 3-4. Gasifier Combustor Emissions

<u>Performance</u>	
Product Gas Produced (MMBtu/hr)	376
Quantity of Residual Char (%)	33.0
Heat Input from Residual Char (MMBtu/hr)	124
Char Heating Value (Btu/lb)	14,500
Hours of Operation	8,760
 <u>Stack Parameters</u>	
Diameter (ft)	TBD
Height (ft)	TBD
Temperature (°F)	TBD
Velocity (ft/sec)	TBD
Flow (acfm)	TBD
 <u>Emissions</u>	
SO ₂ -Basis is feedstock organic sulfur content (%)	0.004
Feedstock Rate (dry TPD)	730
(lb/hr)	2.4
(tpy)	10.7
NO _x - (lb/MMBtu) Battelle Report, 1989	0.05
(lb/hr)	6.2
(tpy)	27.2
CO - (lb/ton) AP-42, Table 1.2-2	0.6
Char produced (ton/hr)	4.3
(lb/hr)	2.6
(tpy)	11.2
VOC - (lb/ton) AP-42, Table 1.2-6	0.3
Char produced (ton/hr)	4.3
(lb/hr)	1.3
(tpy)	5.6
PM/PM10-(lb/ton) AP-42, Table 1.2-3	71.2
Char produced (ton/hr)	4.3
(lb/hr)	304.6
Cyclone/Baghouse Efficiency (%)	98.0
(tpy)	26.7

Table 3-5. Material Handling Emissions

Vibrating Grate Baghouse (FS001)			
Parameters		Value	Units Source
Flow Rating of Baghouse (V)		2,500	scfm ASSUMED
Emission Factor (EF)		0.03	gr/dscf Default EF from 62-296.711 FAC
Emission Rate (ER)		2.83	tpy ER = EF * V * 60 * 8760 / 2000 / 7000

Front End Loader Fugitive PM ₁₀ Emissions (FS002)			
Parameters		Value	Units Source
Vehicle Data			
Vehicle weight: (W _L)	Loaded	30.00	ton ASSUMED
(W _U)	Unloaded	27.25	ton ASSUMED
(W _{AVG})	Average	28.625	ton W _{AVG} = (W _L + W _U) / 2
Material throughput (M)	Annual	365,000	tons/yr ASSUMED
Vehicle capacity (C)		2.8	ton C = W _L - W _U
Number of vehicles (V)	Annual	132,727	vehicles V = M / C
Distance traveled/ vehicle/ route (D)	Per trip	0.076	miles Assume 400 feet (width of building across and back)
VMT (D _{VMT})	Annual	10,055.1	VMT/yr D _{VMT} = D _T * V
General/ Site Characteristics			
Days of precipitation greater than or equal to 0.254 mm (P)	Annual	0	days Located under covered area
Silt content (s)		8.4	% AP-42 13.2.2 Unpaved Roads
Particle size multiplier, PM ₁₀ (k)		1.5	lb/VMT AP-42 13.2.2 Unpaved Roads
Emission Factor Equation			
EF _{UNC} (lb/VMT) = k(s/12) ^{0.9} (W _{AVG}) ^{0.44} [(365-P)/365]			
Calculated PM ₁₀ Emission Factor Uncontrolled EF (EF _{UNC})	Annual	3.003	lb/VMT AP-42 13.2.2 eq. 1a
Calculated PM₁₀ Emission Rates			
Uncontrolled Emissions (E _{UNC})	Annual	15.1	tpy E _{UNC} = EF _{UNC} * D _{VMT} / 2000

Stacker Transfer Point Baghouse (FS003)			
Parameters		Value	Units Source
Flow Rating of Baghouse (V)		1,000	scfm ASSUMED
Emission Factor (EF)		0.03	gr/dscf Default EF from 62-296.711 FAC
Emission Rate (ER)		1.13	tpy ER = EF * V * 60 * 8760 / 2000 / 7000

Stacker Conveyor Dropping Material onto Pile (FS004)			
Parameters		Value	Units Source
Material throughput (M)	Annual	365,000	tons/yr ASSUMED
Mean Wind Speed		6.3	mph AP 42 Table 7.1.9 Tallahassee, FL
Material Moisture Content (U)		4.8	% (A)
K		0.35	AP 42 Table 13.2.4
EF		0.00044	lb/ton EF = k * 0.0032 * ((U/5) ^{1.3}) / ((M/2) ^{1.4})
E	Annual	0.08	tpy E = M * EF

Front End Loader Dropping Biomass onto Reclaimer Elevator (FS005)			
Parameters		Value	Units Source
Material throughput (M)	Annual	365,000	tons/yr ASSUMED
Mean Wind Speed		6.3	mph AP 42 Table 7.1.9 Tallahassee, FL
Material Moisture Content (U)		4.8	% (A)
K		0.35	AP 42 Table 13.2.4
EF		0.00044	lb/ton EF = k * 0.0032 * ((U/5) ^{1.3}) / ((M/2) ^{1.4})
E	Annual	0.08	tpy E = M * EF

Drier/Fuel Silo Baghouse (FS006)			
Parameters		Value	Units Source
Flow Rating of Baghouse (V)		1,000	scfm ASSUMED - Probably will be higher for a drier
Emission Factor (EF)		0.03	gr/dscf Default EF from 62-296.711 FAC
Emission Rate (ER)		1.13	tpy ER = EF * V * 60 * 8760 / 2000 / 7000

Fuel Silo Screw Auger Baghouse (FS007)			
Parameters		Value	Units Source
Flow Rating of Baghouse (V)		1,000	scfm ASSUMED
Emission Factor (EF)		0.03	gr/dscf Default EF from 62-296.711 FAC
Emission Rate (ER)		1.13	tpy ER = EF * V * 60 * 8760 / 2000 / 7000

Gassifier Fuel Bin Vent Filter (FS008)			
Parameters		Value	Units Source
Material throughput (M)	Annual	365,000	tons/yr ASSUMED
Emission Factor (EF)		0.0063	lb/ton AP-42 9.9.1-1 Storage Bin
Control (C)		99.9%	ASSUMED
Emission Rate (ER)	Annual	0.00	tpy E = M * EF * (1-C)/1

Sand (Olivine) System Baghouse (FS009)			
Parameters		Value	Units Source
Material throughput (M)	Annual	37	lb/hr MATERIAL BALANCE
Emission Factor (EF)		162.1	tpy 8,760 lb/yr
Control (C)		99.9%	ASSUMED
Emission Rate (ER)	Annual	0.16	tpy E = M * (8,760/2000) * (1-C)/1

Ash System Baghouse (FS010)			
Parameters		Value	Units Source
Material throughput (M)	Annual	550	lb/hr MATERIAL BALANCE
Emission Factor (EF)		2409	tpy 8,760 lb/yr
Control (C)		99.9%	ASSUMED
Emission Rate (ER)	Annual	2.41	tpy E = M * (8,760/2000) * (1-C)/1

Total PM ₁₀ Emissions			
Parameters		Value	Units Source
Total PM ₁₀ Emissions from fugitive sources	Annual	24.0	tpy Sum of Fugitive Sources

(A) Wet wood is 30% moisture; however, this emission factor is only valid for material up to a moisture content of 4.8%. This value has been used which is conservative

Table 3-6. Feedstock Dryer EmissionsPerformance

Dry wood produced 266,450 dry tpy Dry wood from dryer

Emissions

PM - Emission Factor 0.72 lb/ton dry wood AP42 Table 10.6-1
 Control 99.9% Baghouse Efficiency
 Emission Rate **0.10** tpy Emission Rate = Emission Factor * Dry Wood Produced

PM₁₀ - Emission Factor 0.062 lb/ton dry wood AP42 Table 10.6-1
 Control 99.9% Baghouse Efficiency
 Emission Rate **0.01** tpy Emission Rate = Emission Factor * Dry Wood Produced

AP-42, Table 10.6-1 also provides factors for SO₂, NO_x, CO, and CO₂ emissions for indirect dryers; however, drying is by heat exchange, there is no combustion proposed.

Table 3-7. Performance, Stack Parameters and Emissions for Auxiliary Boiler

<u>Performance</u>	
Fuel Usage (scf/hr-gas)	60,713
Heat Input (mmBtu/hr-HHV)	62.00
Hours per Year	500
Maximum Fuel Usage (mmscf/yr)	30.36
<u>Stack Parameters</u>	
Diameter (ft)	2.75
Height (ft)	50
Temperature (°F)	296
Velocity (ft/sec)	81
Flow (acfm)	29,000
<u>Emissions</u>	
SO ₂ -Basis (grains S/100 scf-gas; %S diesel)	2.00
(lb/hr)	0.35
(tpy)	0.09
NO _x - (lb/mmBtu)	0.095
(lb/hr)	5.89
(tpy)	1.47
CO - (lb/mmBtu)	0.08
(lb/hr)	4.96
(tpy)	1.24
VOC - (lb/mmBtu)	0.005
(lb/hr)	0.31
(tpy)	0.08
PM/PM10 - (lb/10 ⁶ ft ³)	1.90
(lb/hr)	0.12
(tpy)	0.03

Table 3-8. Flare System Emissions

<u>Parameter</u>		<u>Value</u>	<u>Units</u>	<u>Source/Description</u>
Fuel Flow		19,627	lbm/hr	Gas Analysis 18-Oct -07, Solar
Energy Density		7,337	Btu/lbm	Gas Analysis 18-Oct -07, Solar, Low Heating Value of fuel
Energy Input to Flare		144	MMBtu/hr	Energy Input = Fuel Flow * Energy Density / 1,000,000
<u>Emissions</u>				
TOC -	Emission Factor	0.14	lb/MMBtu	AP-42 Table 13.5-1
	Emission Rate	20.2	lb/hr	Emission Rate = Emission Factor * Energy Input
	Emission Rate	1.5	tpy	Emission Rate (tpy) = Emission Rate (lb/hr) * 8760 /2000
CO -	Emission Factor	0.37	lb/MMBtu	AP-42 Table 13.5-1
	Emission Rate	53.3	lb/hr	Emission Rate = Emission Factor * Energy Input
	Emission Rate	3.8	tpy	Emission Rate (tpy) = Emission Rate (lb/hr) * 8760 /2000
NO _x -	Emission Factor	0.068	lb/MMBtu	AP-42 Table 13.5-1
	Emission Rate	9.8	lb/hr	Emission Rate = Emission Factor * Energy Input
	Emission Rate	0.7	tpy	Emission Rate (tpy) = Emission Rate (lb/hr) * 8760 /2000
SO ₂ (Based on Mass Balance) -	Heating Value	435.0	Btu/scf	Heating Value of Syngas @ 14.7 psia & 60°F
	Syngas Flow	331,042.1	scf/hr	144 MMBtu * 1,000,000 / 435 btu/scf
	H ₂ S in syngas	0.02	% by vol	Gas Analysis 18-Oct -07, Solar
	H ₂ S Flow	66.2	scf/hr	86687 scfm * 0.0002 vol %
	gas constant	0.0029	cf-atm/mol-K	Constant
	H ₂ S Molar Flow	79.1	g-mol/hr	n= (1 atm) * (17.34 scfm) / (0.0029 cf-atm/mol-K) / (288.7K)
	MW SO ₂	64.1	g/g-mol	1 mol of H ₂ S forms 1 mol of SO ₂
	SO ₂ Mass Flow	5,072.8	g/hr	20.7 gmol/hr * 64.1 g/gmol
	SO ₂ Mass Flow	11.2	lb/hr	5072 g/hr / 453.59 g/lb
	SO ₂ Mass Flow	0.8	tpy	11.2 lb/hr * 8760 / 2000
Soot (PM) -	AP-42, Table 13.5-1--- fuels with a C:H ratio of less than 0.33 tend not to soot. The average C:H ratio in the syngas is less than 0.33.			

Table 3-9. Physical, Performance, and Emissions Data for the Mechanical Draft Cooling Towers

Parameter	Steam Turbine Cooling	Compressor Gas Cooling
<u>Physical Data</u>		
Number of Cells	2	3
Deck Dimensions, ft		
Length	96.5	16.4
Width	33.5	12.2
Height(Tower Height)	32.3	17.5
Stack Dimensions		
Height, ft	10.0	5.2
Stack Top Effective Inner Diameter, per cell, ft	21.5	9.0
Effective Diameter, all cells, ft	TBD	TBD
<u>Performance Data (per cell)</u>		
Discharge Velocity, ft/min	1,690	1,799
Circulating Water Flow Rate (CWFR), gal/min	7,050	3,800
Design hot water temperature, °F	113.7	95
Design Air Flow Rate per cell, acfm, (estimated)	1,061,664	114,386
Hours of operation	8,760	8,760
<u>Emission Data</u>		
Drift Rate ^a (DR), percent	0.0020	0.0050
Total Dissolved Solids (TDS) Concentration ^b , average ppm	2,000	1,000
Solution Drift ^c (SD), lb/hr	70.2	94.6
PM Drift ^d , lb/hr	0.14	0.09
tons/year	0.6	0.4
PM ₁₀ Drift ^e		
PM ₁₀ Emissions, lb/hr	0.09	0.08
tons/year	0.4	0.3

^a Drift rate is the percent of circulating water.

^b The TDS values assumed are conservative and include cycling.

^c Includes water and based on circulating water flow rate and drift rate (CWFR x DR x 8.3 lb/gal x 60 min/hr).

^d PM calculated based on total dissolved solids and solution drift (TDS x SD).

^e PM₁₀ based on Cooling Tower PM₁₀ emissions study see Attachment A.


Source: Solar, 2008; Golder, 2008.

TDS (ppmw)	PM Emission Rate (lb/hr)	Percent of Emissions < or = PM10 %	PM10 Emissions (lb/hr)
1000	0.09	82.04	0.078
2000	0.19	63.50	0.120
3000	0.28	50.00	0.142
4000	0.38	38.33	0.145
5000	0.47	29.97	0.142
6000	0.57	23.59	0.134
7000	0.66	18.20	0.121
8000	0.76	13.57	0.103
9000	0.85	9.65	0.082
10000	0.95	6.28	0.059
11000	1.04	5.11	0.053
12000	1.14	4.46	0.051
25307	2.39	1.07	0.026
29000	2.74	0.82	0.023
89600	8.48	0.22	0.019


Tower Circulation Rate (GPM)	3,800
Drift Rate %	0.005

Calculated PM10 %
< or = PM10 %

water density (lb/gal)	8.3
Calculated PM10 %	82.04
	63.50
	50.00
	38.33
	29.97
	23.59
	18.20
	13.57
	9.65
	6.28
	5.11
	4.46
	1.07
	0.82
	0.22



Source: Reisman, Joel and Gordon Frisbie, Calculating Realistic PM10 Emissions from Cooling Towers, Abstract No. 216, Greystone Environmental Consultants, Inc.




Reisman, Joel and Gordon Frisbie, *Calculating Realistic PM10 Emissions from Cooling Towers*, Abstract No. 216, Greystone Environmental Consultants, Inc.

TDS (ppmw)	PM Emission Rate (lb/hr)	Percent of Emissions < or = PM10 %	PM10 Emissions (lb/hr)
1000	0.07	82.04	0.058
2000	0.14	63.50	0.089
3000	0.21	50.00	0.105
4000	0.28	38.33	0.108
5000	0.35	29.97	0.105
6000	0.42	23.59	0.099
7000	0.49	18.20	0.090
8000	0.56	13.57	0.076
9000	0.63	9.65	0.061
10000	0.70	6.28	0.044
11000	0.77	5.11	0.040
12000	0.84	4.46	0.038
25307	1.78	1.07	0.019
29000	2.04	0.82	0.017
89600	6.30	0.22	0.014

Tower Circulation Rate (GPM)	Drift Rate %	Calculated PM10 % < or = PM10
7,056	0.002	82.04
		63.50
		50.00
		38.33
		29.97
		23.59
		18.20
		13.57
		9.65
		6.28
		5.11
		4.46
		1.07
		0.82
		0.22

water density (lb/gal) 8.3


Percentage of Drift PM that Evaporates to PM10



Source: Reisman, Joel and Gordon Frisbie, Calculating Realistic PM10 Emissions from Cooling Towers, Abstract No. 216, Greystone Environmental Consultants, Inc.

PM10 Emission Rate vs TDS

Data presented for wet cooling tower with water circulation rate of 306,000 GPM and 0.0005% drift rate.



Reisman, Joel and Gordon Frisbie, Calculating Realistic PM10 Emissions from Cooling Towers, Abstract No. 216, Greystone Environmental Consultants, Inc.

Table ST Cooling. Resultant Solid Particulate Size Distribution (TDS = 2000 ppmw)

EPRI Droplet Diameter (um)	Droplet Volume (um ³)	Droplet Mass (ug)	Particulate Mass (Solids) (ug)	Solid Particulate Volume (um ³)	Solid Particulate Diameter (um)	EPRI % Mass Smaller	Calculated PM10 % fraction to < or = PM10
10	523.6	5.24E-04	1.05E-06	0.48	0.969	0.000	
20	4188.8	4.19E-03	8.38E-06	3.81	1.937	0.196	
30	14137.2	1.41E-02	2.83E-05	12.85	2.906	0.226	
40	33510.3	3.35E-02	6.70E-05	30.46	3.875	0.514	
50	65449.8	6.54E-02	1.31E-04	59.50	4.844	1.816	
60	113097.3	1.13E-01	2.26E-04	102.82	5.812	5.702	
70	179594.4	1.80E-01	3.59E-04	163.27	6.781	21.348	
90	381703.5	3.82E-01	7.63E-04	347.00	8.719	49.812	63.5
110	696910.0	6.97E-01	1.39E-03	633.55	10.656	70.509	
130	1150346.5	1.15E+00	2.30E-03	1045.77	12.593	82.023	
150	1767145.9	1.77E+00	3.53E-03	1606.50	14.531	88.012	
180	3053628.1	3.05E+00	6.11E-03	2776.03	17.437	91.032	
210	4849048.3	4.85E+00	9.70E-03	4408.23	20.343	92.468	
240	7238229.5	7.24E+00	1.45E-02	6580.21	23.250	94.091	
270	10305994.7	1.03E+01	2.06E-02	9369.09	26.156	94.689	
300	14137166.9	1.41E+01	2.83E-02	12851.97	29.062	96.288	
350	22449297.5	2.24E+01	4.49E-02	20408.45	33.906	97.011	
400	33510321.6	3.35E+01	6.70E-02	30463.93	38.749	98.340	
450	47712938.4	4.77E+01	9.54E-02	43375.40	43.593	99.071	
500	65449846.9	6.54E+01	1.31E-01	59499.86	48.436	99.071	
600	113097335.5	1.13E+02	2.26E-01	102815.76	58.124	100.000	






Table #. Resultant Solid Particulate Size Distribution (TDS = 1000 ppmw)

EPRI Droplet Diameter (um)	Droplet Volume (um3)	Droplet Mass (ug)	Particulate Mass (Solids) (ug)	Solid Particulate Volume (um3)	Solid Particulate Diameter (um)	EPRI % Mass Smaller
10	523.6	5.24E-04	5.24E-07	0.24	0.769	0.000
20	4188.8	4.19E-03	4.19E-06	1.90	1.538	0.196
30	14137.2	1.41E-02	1.41E-05	6.43	2.307	0.226
40	33510.3	3.35E-02	3.35E-05	15.23	3.076	0.514
50	65449.8	6.54E-02	6.54E-05	29.75	3.844	1.816
60	113097.3	1.13E-01	1.13E-04	51.41	4.613	5.702
70	179594.4	1.80E-01	1.80E-04	81.63	5.382	21.348
90	381703.5	3.82E-01	3.82E-04	173.50	6.920	49.812
110	696910.0	6.97E-01	6.97E-04	316.78	8.458	70.509
130	1150346.5	1.15E+00	1.15E-03	522.88	9.995	82.023
150	1767145.9	1.77E+00	1.77E-03	803.25	11.533	88.012
180	3053628.1	3.05E+00	3.05E-03	1388.01	13.840	91.032
210	4849048.3	4.85E+00	4.85E-03	2204.11	16.147	92.468
240	7238229.5	7.24E+00	7.24E-03	3290.10	18.453	94.091
270	10305994.7	1.03E+01	1.03E-02	4684.54	20.760	94.689
300	14137166.9	1.41E+01	1.41E-02	6425.98	23.066	96.288
350	22449297.5	2.24E+01	2.24E-02	10204.23	26.911	97.011
400	33510321.6	3.35E+01	3.35E-02	15231.96	30.755	98.340
450	47712938.4	4.77E+01	4.77E-02	21687.70	34.600	99.071
500	65449846.9	6.54E+01	6.54E-02	29749.93	38.444	99.071
600	113097335.5	1.13E+02	1.13E-01	51407.88	46.133	100.000

Calculated PM10 %
fraction to
PM10 < or = PM10
%

0.00296 82.0





LEGEND

 Project Location




PROJECT	BG&E LEON COUNTY, FLORIDA		
TITLE	PROJECT SITE LOCATION		
 Golder Associates Tampa, Florida	PROJECT No	073-89524	SCALE AS SHOWN
	DESIGN	PB 01/00/08	REV 0
	GIS	PB 01/00/08	
	CHECK	RZ 01/00/08	
	REVIEW	RZ 01/00/08	

FIGURE 2-1

REFERENCES

1. County boundaries - Florida Department of Environmental Protection
2. Roads & Railroads - ESRI StreetMap

DRAFT

D:\Projects\2008\073-89524\073-89524.mxd




Figure 2-2.
Project Site Layout

POWER PLANT COMPONENT LEGEND

- 1 - PREPARED FUEL STORAGE (200'x400') (BGE)
- 2 - GASSIFIER (195'x306') (SILVAGAS)
- 3 - WASTE HEAT RECOVERY UNIT(SILVAGAS)
- 4 - PRODUCT GAS CLEANING (90'x167') (SILVAGAS)-DAHLMAN
- 5 -
- 6 - ELECTRICAL DISTRIBUTION (15'x30') (BGE)
- 7A- COOLING TOWER - STEAM CONDENSOR (SOLAR)
- 7B- COOLING TOWER - STEAM CONDENSOR (SOLAR)
- 7C- COOLING TOWER - PROCESS COOLING WATER (SOLAR)
- 7D- COOLING TOWER - PROCESS COOLING WATER (SOLAR)
- 8 - STEAM TURBINE (SOLAR)
- 9 - SOLAR TITAN 130 (SOLAR)
- 10 - SOLAR TITAN 130 (SOLAR)
- 11 - PRODUCT GAS COMPRESSORS (80'x80') (SOLAR)
- 12 - OGEN SUBSTATION (40'x80') (BGE)
- 13 - EXISTING SUBSTATION
- 14 - POWER BUILDING (SOLAR)
- 15 - OFFICE (50'x120') (BGE)
- 16 - MAINTENANCE BUILDING (BGE)
- 17 - FIREWATER TANK (20'DIA.) (BGE)
- 18 - STORM WATER RETENTION POND (BGE)
- 19 - WATER TREATMENT BUILDING & TANKS (SOLAR)
- 20 - FIRE WATER PUMP (DIESEL) & FIRE WATER JOCKEY PUMP (BGE)
- 21 - 13.8 SWITCHGEAR BUILDING
- 22 - AMMONIA BULK STORAGE
- 23 - FSU BUILDING (50'x100')

LEGEND

	PROPERTY BOUNDARY
	BUILDING SETBACK/LANDSCAPE BUFFERS
	RAIL SPUR CENTERLINE

NOTES:

1. BOUNDARY AND TOPOGRAPHIC INFORMATION PREPARED BY BROWARD, DAVIS AND ASSOCIATES AND RECEIVED ELECTRONICALLY ON 10/22/07.
2. SITE PLAN FEATURES PREPARED BY SOLAR TURBINES AND RECEIVED ELECTRONICALLY ON 01/10/08.
3. A COMPLETE STORMWATER ANALYSIS HAS NOT BEEN PERFORMED.

P.O.C.
AT A CONCRETE MONUMENT MARKING THE SOUTHWEST CORNER OF THE EAST HALF OF THE NORTHWEST QUARTER OF SECTION 3, TOWNSHIP 1 SOUTH, RANGE 1 WEST, LEON COUNTY, FLORIDA.

REV	DATE	DRWN BY	CHKD BY	APVD BY	DESCRIPTION
REVISIONS					
Ford, Bacon & Davis <small>A Standard Liability Company</small>					
BIOMASS POWER PLANT					
PB&D JOB NUMBER: Y7211 SCALE: NO SCALE DATE: 03/12/08 DRAWN BY: K. SCHUBBS					REV. A
CONCEPTUAL SITE PLAN					




FIGURE 2-3
PROJECT PROCESS SCHEMATIC

REV	DATE	DRWN BY	CHKD BY	APVD BY	DESCRIPTION
A	03/13/08				FOR INFORMATION


Ford, Bacon & Davis
A Lockheed Martin Company

BG&E TALLAHASSEE PLANT
PROJECT FLOW SCHEMATIC

PFD JOB NUMBER: Y7211
SCALE: NO SCALE
DATE: 03/03/2008
DRAWN BY: S. MURPHY

PFD-ALL AREAS-01

REV. A




LEGEND

- MATERIAL FLOW
- - - - DUST COLLECTION
- - - - EXHAUST AIR

NOTES

- 1.) INFORMATION PROVIDED IN THIS DRAWING IS FOR CONCEPTUAL PURPOSE ONLY, NOT FOR CONSTRUCTION.
- 2.) ALL CONVEYORS SHALL HAVE COVERS TO PROVIDE WIND AND RAIN PROTECTION.
- 3.) NOT ALL EQUIPMENT ARE SHOWN ON THIS DRAWING.
- 4.) COMPRESSED AIR REQUIRED FOR BAG FILTER CLEANING IS NOT SHOWN.
- 5.) DUST HOODS TO BE INSTALLED AT BELT CONVEYOR HEAD PULLEYS AND TRANSFER POINTS. DUST HOOD EXHAUST TO BE CONNECTED TO DUST COLLECTOR SYSTEMS. DUST HOODS TO BE EQUIPPED WITH RUBBER SKIRTS AND CURTAINS TO MINIMIZE FUGITIVE DUST EMISSIONS.



REV	DATE	DES	REVISION DESCRIPTION	CADD	CHK	RW
PROJECT: BIOMASS GAS & ELECTRIC TALLAHASSEE PROJECT ROBERTS ROAD TRACT LEON COUNTY, FLORIDA						
TITLE: MATERIAL HANDLING PROCESS SCHEMATIC						
PROJECT No. 073-89628		FILE No. 07389628A001				
DESIGN	PSM	02/28/03	SCALE	NONE	REV.	0
CADD	YPW	02/28/08				
CHECK	PSM	03/31/08				
REVIEW	KGK	03/31/08				



FIGURE 2-4

Project File: 0738962807.DWG | Layout: Support | Modified: 03/27/08 4:15pm | Plotted: 03/27/08 4:15pm | Plotted by: p...